



Arcoplast


Energy Savings Analysis




Food Processing Facility Case Study

10,000 ft² Food Processing Facility Case Study Model

Dimensions: 100' x 100' x 27'
Outside Ambient: 95 F
Solar Load: 1040 W/m²
Desired Internal Floor Temp: 40 F



10,000 ft² Food Processing Facility Case Study Model



Ceiling Panel Insulative Properties


Panel	Actual thickness (in)	Thermal Conductivity (W/m-K)	Thermal Conductivity (BTU-in/hr-ft ² -F)	Leakage at 0.01 in-H ₂ O ΔP (CFM/ft ²)
½" Closed Edge Insulation panel, Gel Coat Finish	0.654	0.040	0.276	0.0
1" Closed Edge Insulation panel, Gel Coat Finish	1.153	0.037	0.255	0.0
1-½" Closed Edge Insulation panel, Gel Coat Finish	1.678	0.036	0.252	0.0
2" Closed Edge Insulated panel, Gel Coat Finish	2.171	0.038	0.260	0.0
3/8" glass board panel	0.366	0.101	0.698	0.0

Food Processing Facility Case Study


*Nominal 3/8" Glass Board Panel
(Actual thickness: 0.366 in)
95 F ambient during the day*

Food Processing Facility Model Results - 3/8" Glass Board

Temperature
Roof Exterior




[F]




Food Processing Facility Model Results - 3/8" Glass Board

Temperature
Air Section



[F]



Ceiling Air Space



Peak Temp: 207 F

Avg. Temp: 115 F

Min Temp: 77 F

*Lower minimum temperature means
increased risk for condensation on top
of panels*

Temperature shown at
cross section indicated




Room Air Space

Avg. Temp: ~ 40 F

Food Processing Facility Model Results - 3/8" Glass Board


Temperature
Panels



Panel Delta T: ~22 F
Does not insulate well



Temperature shown at
cross section indicated



Additional Cooling* needed: ~21.25 Tons (255,000 BTU/hr per 10000 ft²)
Excessive energy is lost through the panel

**In addition to heat generated from process equipment and persons*


Topside Heat transfer coefficient: 0.73 BTU/hr-ft²-F
Underside Heat transfer coefficient: 1.68 BTU/hr-ft²-F

Food Processing Facility Case Study


*Nominal 2" Closed Edge Insulating Panel, Gel Coat Finish
(Actual thickness: 2.171 in)
95 F ambient during the day*

Food Processing Facility Model Results - 2" Insulated


Temperature
Roof Exterior



[F]





Peak Roof Temperature: 211 F





Food Processing Facility Model Results - 2" Insulated

Temperature
Air Section



Ceiling Air Space
Peak Temp: 208 F
Avg. Temp: 120 F
Min Temp: 90 F


Temperature shown at
cross section indicated




Room Air Space
Avg. Temp: ~ 40 F

Food Processing Facility Model Results - 2" Insulated

Temperature
Panels




[F]



Panel Delta T: 67 F

Temperature shown at
cross section indicated




Additional Cooling* needed: ~6.5 Tons (76020 BTU/hr per 10000 ft²)

Vast reduction from the 21.25 Tons required with the 3/8" glass board panels



****In addition to heat generated from process equipment and persons***

Topside Heat transfer coefficient: 0.50 BTU/hr-ft²-F
Underside Heat transfer coefficient: 1.68 BTU/hr-ft²-F


Food Processing Facility Model - Comparison



The 2" Closed Edge Insulated Panel decreases heat transfer from the interstitial space to the process area by **70%** versus the 3/8" Glass Board Panel



Heat Transfer Pathway



Food Processing Facility Cooling Calculations

$$R_{conduction} = \frac{L}{k}$$

$$R_{total} = R_{conv_{ceiling}} + R_{cond_{panels}} + R_{conv_{floor}}$$

$$R_{convection} = \frac{1}{h}$$

$$Q_{heat} = \frac{(T_{hot} - T_{cold}) A}{R_{total}}$$

h	Heat Transfer Coefficient
k	Thermal Conductivity
A	Total Area of Panels
L	Thickness of Panels
T	Temperature
R	Resistance
Q	Heat Transfer

Panel Type	$h_{ceiling}$ (BTU/hr-ft ² -F)	h_{floor} (BTU/hr-ft ² -F)	K (BTU-in/hr-ft ² -F)	L (in)	$R_{conv_ceiling}$	R_{cond}	R_{conv_floor}	R_{total}
3/8" Glass Board Panel	0.617	1.68	0.698	0.366	1.62	0.524	0.594	2.739
2" Closed Edge Insulated Panel	0.617	1.68	0.260	2.171	1.62	8.350	0.594	10.56

Panel Type	$T_{ceiling}$ (F)	T_{floor} (F)	A (ft ²)	R_{total}	Q (BTU/hr)	AC Sizing
3/8" Glass Board Panel	120	40	10,000	2.739	292,098	+ 24.50 Ton
2" Closed Edge Insulated Panel	120	40	10,000	10.56	75,726	+ 6.5 Ton

Heat Transfer for 3/8" Glass Board Panel: **292,098 BTU/hr**

Heat Transfer for 2" Closed Edge Insulated Panel: **75,726 BTU/hr**

Energy Loss Ratio: **3.85**

Will require additional capital investment for a larger AC unit(s)

Additional **18 Tons** of cooling solely due to heat transfer from the interstitial space

Food Processing Facility Air Conditioning Cost

$$EER = \frac{\text{Panel Heat Transfer} \left[\frac{BTU}{hr} \right]}{AC \text{ Input Power} [W]}$$

Panel Type	Average Cost of Electricity in USA (¢/kWh)	Panel Heat Transfer (BTU/hr)	AC Efficiency - EER	AC Power Input (kW)	Additional Cost Per Hour (95 F day) (\$)
3/8" Glass Board Panel	14.2	292,098	8.5	34.4	\$ 4.88
2" Closed Edge Insulated Panel	14.2	75,726	8.5	8.91	\$ 1.27

Panel Type	Summer Cost (95 F day) 5 Months, 12 Hours a Day (\$)	Spring/Fall Cost (80 F day) 4 Months, 12 Hours a Day (\$)	Winter Cost (65 F day) 3 Months, 12 Hours a Day (\$)
3/8" Glass Board Panel	\$8,783	\$5,110	\$2,396
2" Closed Edge Insulated Panel	\$2,277	\$1,325	\$621

Panel Type	Summer Cost (80 F night) 5 Months, 12 Hours a Day (\$)	Spring/Fall Cost (65 F night) 4 Months, 12 Hours a Day (\$)	Winter Cost (50 F night) 3 Months, 12 Hours a Day (\$)	Additional Total Cost Per Year (\$)
3/8" Glass Board Panel	\$ 6,388	\$ 3,194	\$ 958	\$ 26,829
2" Closed Edge Insulated Panel	\$ 1,656	\$ 828	\$ 248	\$ 6,955
Savings per year				\$ 19,874

One year air conditioning cost for 3/8" Glass Board Panel: **\$ 26,829**

One year air conditioning cost for 2" Closed Edge Insulated Panel: **\$ 6,955**

Savings Per Year for 10,000 ft²: \$ 19,874

Food Processing Facility Air Conditioning Cost


Panel Type	Actual Thickness (in)	R _{cond}	R _{floor+ceiling}	Panel Heat Transfer per 10000 ft ² (BTU/hr)	AC Sizing*	Additional Cooling* Cost per Year (\$)	Savings per year vs. 3/8" Glass board panel (\$)
3/8" Glass Board Panel	0.366	0.524	2.214	292,098	+ 24.5 Tons	\$ 26,829	
½" Closed Edge Insulated Panel	0.654	2.370	2.214	174,501	+ 14.5 Tons	\$ 16,028	\$ 10,801
1" Closed Edge Insulated Panel	1.153	4.522	2.214	118,756	+ 10.0 Tons	\$ 10,908	\$ 15,921
1-½" Closed Edge Insulated Panel	1.678	6.659	2.214	90,155	+ 7.5 Tons	\$ 8,281	\$ 18,548
2" Closed Edge Insulated Panel	2.171	8.350	2.214	75,726	+ 6.5 Tons	\$ 6,955	\$ 19,874

* In addition to cooling needed for heat generation from process equipment and persons


Data Center Facility Case Study

10,000 ft² Data Center Facility Case Study Model

Dimensions: 100' x 100' x 28'
Outside Ambient: 95 F
Solar Load: 1040 W/m²
Desired Internal Floor Temp: 70 F



10,000 ft² Data Center Facility Case Study Model




Mineral Ceiling Panels



Equivalent Porosity: 0.8565
Equivalent packed bed bead diam.: 0.0036 inch

Leakage at a building positive pressure of 0.01 inch-H₂O: 1.9 CFM/ft²



Ceiling Panel Insulative Properties

Panel	Actual thickness (in)	Thermal Conductivity (W/m-K)	Thermal Conductivity (BTU-in/hr-ft ² -F)	Leakage at 0.01 in-H ₂ O ΔP (CFM/ft ²)
½" Closed Edge Insulation panel, Gel Coat Finish	0.654	0.040	0.276	0.0
1" Closed Edge Insulation panel, Gel Coat Finish	1.153	0.037	0.255	0.0
1-½" Closed Edge Insulation panel, Gel Coat Finish	1.678	0.036	0.252	0.0
2" Closed Edge Insulated panel, Gel Coat Finish	2.171	0.038	0.260	0.0
3/8" glass board panel	0.366	0.101	0.698	0.0
5/8" mineral ceiling panel	0.625	0.055*	0.376*	1.9

***Note: Thermal conductivity assumes no mass transfer effects.**

Data Center Facility Case Study



Nominal 2" Closed Edge Insulating Panel, Gel Coat Finish

(Actual thickness: 2.171 in)

95 F ambient during the day


Data Center Facility Model Results – 2” Insulated

Temperature
Roof Exterior




Data Center Facility Model Results – 2" Insulated


Temperature
Air Section




[F]



Temperature shown at
cross section indicated




Ceiling Air Space
Peak Temp: 209 F
Avg. Temp: 127 F
Min Temp: 103 F




Room Air Space
Avg. Temp: 70 F

Data Center Facility Model Results – 2" Insulated


Temperature
Panels



[F]




Temperature shown at
cross section indicated



Panel Delta T: ~30 F


Additional Cooling* needed: ~2.5 Tons
(29,915 BTU/hr per 10000 ft²)

**In addition to heat generated from electrical equipment*




Data Center Facility Model Results – 2" Insulated

Velocity (Projection)
Ceiling and Room Vector



Vectors shown at cross section indicated




Only method of energy loss is due to convection on either side of ceiling panel and conduction through it.

No flow through panels.


Data Center Facility Case Study

5/8" Mineral Ceiling Tile
95 F ambient during the day

Data Center Facility Model Results – 5/8” Mineral Tile




Data Center Facility Model Results – 5/8" Mineral Tile




Data Center Facility Model Results – 5/8" Mineral Tile


Temperature
Panels



[F]



Temperature shown at
cross section indicated



Panel Delta T: < 1 F
Mass transfer effects dominate




Additional Cooling* needed: ~30.0 Tons (359,600 BTU/hr per 10000 ft²)

2" Insulated panels only requires an additional 2.5 Tons of cooling


**In addition to heat generated from electrical equipment*

Data Center Facility Model Results – 5/8" Mineral Tile

Velocity (Projection)
Ceiling and Room Vector



Vectors shown at cross
section indicated




Velocities are similar in the room but due to the porosity of the mineral ceiling tiles, air is able to permeate through and reach the hot underside of the roof

Air permeation rate: 1475 CFM



Data Center Facility Model Comparison

Static Enthalpy Gradient
Panel Energy Transfer




Due to air leakage, heat transfer through the 5/8" mineral ceiling tile is **12 times** greater than the 2" Closed Edge insulated panel

Use of mineral ceiling panels would require an additional capital investment of a larger AC unit(s)



Mineral Ceiling Tile Heat Transfer Pathway



Data Center Facility Air Conditioning Cost

$$EER = \frac{\text{Panel Heat Transfer} \left[\frac{BTU}{hr} \right]}{AC \text{ Input Power} [W]}$$

Panel Type	Average Cost of Electricity in USA (¢/kWh)	Panel Heat Transfer (BTU/hr)	AC Efficiency - EER	AC Power Input (kW)	Additional Cost Per Hour (95 F day) (\$)	AC Sizing
5/8" Mineral Ceiling Tile	14.2	359,563	9.5	37.85	\$ 5.37	+ 30.0 Tons
2" Closed Edge Insulated Panel	14.2	29,915	9.5	3.15	\$ 0.45	+ 2.5 Tons

Panel Type	Summer Cost (95 F day) 5 Months, 12 Hours a Day (\$)	Spring/Fall Cost (80 F day) 4 Months, 12 Hours a Day (\$)	Winter Cost (65 F day) 3 Months, 12 Hours a Day (\$)
5/8" Mineral Ceiling Tile	\$ 9,674	\$ 3,096	\$ 0
2" Closed Edge Insulated Panel	\$ 805	\$ 257	\$ 0

Panel Type	Summer Cost (80 F night) 5 Months, 12 Hours a Day (\$)	Spring/Fall Cost (65 F night) 4 Months, 12 Hours a Day (\$)	Winter Cost (50 F night) 3 Months, 12 Hours a Day (\$)	Additional Total Cost Per Year (\$)
5/8" Mineral Ceiling Tile	\$ 3,870	\$ 0	\$ 0	\$ 16,640
2" Closed Edge Insulated Panel	\$ 321	\$ 0	\$ 0	\$ 1,384
Savings per year				\$ 15,256

One year air conditioning cost for 5/8" Mineral Ceiling Panel: **\$ 16,640**

One year air conditioning cost for 2" Closed Edge Insulated Panel: **\$ 1,384**

Savings Per Year for 10,000 ft²: \$ 15,256

Data Center Facility Air Conditioning Cost

Panel Type	Actual Thickness (in)	R _{cond}	R _{floor+ceiling}	Panel Heat Transfer per 10000 ft ² (BTU/hr)	AC Sizing*	Additional Cooling* Cost per Year (\$)	Savings per year vs. 5/8" Mineral ceiling tile (\$)
5/8" Mineral Ceiling Tile	0.625			359,563	+ 30.0 Tons	\$ 16,640	
3/8" Glass Board	0.366	0.524	1.678	136,189	+ 11.5 Tons	\$ 6,302	\$ 10,338
½" Closed Edge Insulated Panel	0.654	2.370	1.678	74,110	+ 6.25 Tons	\$ 3,430	\$ 13,210
1" Closed Edge Insulated Panel	1.153	4.522	1.678	48,387	+ 4.0 Tons	\$ 2,239	\$ 14,401
1- ½" Closed Edge Insulated Panel	1.678	6.659	1.678	35,983	+ 3.0 Tons	\$ 1,665	\$ 14,975
2" Closed Edge Insulated Panel	2.171	8.350	1.678	29,915	+ 2.5 Tons	\$ 1,384	\$ 15,256

The majority of the cost savings is due from preventing the air from permeating the interstitial space

* In addition to cooling needed for heat generation from electrical equipment